

INLETS

(SEE PAGE 9 FOR INTERACTIVE WATER PLAY POOLS/SPRAY PADS)

NUMBER OF INLETS = SQUARE FEET OF POOL SURFACE AREA/300 or POOL PERIMETER/20, WHICHEVER IS GREATER

NUMBER OF INLETS = _____ = _____ **ROUND TO NEXT WHOLE NUMBER**

DETERMINING # OF RETURNS NEEDED IN WADING OR TANNING SHELF AREA OF POOL:

- 1. GALLONS (WADING OR TANNING SHELF AREA)/60=NEEDED GPM
- 2. TOTAL DFR OF POOL/TOTAL # OF RETURNS = GPM/RETURN
- 3. # OF RETURNS SHOWN IN WADING OR TANNING SHELF*(GPM/RETURN) SHALL BE > NEEDED GPM

EXAMPLE:

WADING AREA:825 GALLONS	825/60=13.75 (NEEDED GPM)	
WADING POOL TURNOVER RATE: 60 MINUTES		
TOTAL DFR: 240 GPM	240/25=9.6 (DESIGN FLOW/RETURN)	
TOTAL # POOL RETURNS SHOWN: 25		
# RETURNS SHOWN (WADING OR TANNING): 2	2*9.6=19.2	19.2>13.75

SKIMMERS

FOR POOLS: TWO SKIMMERS SHALL BE PROVIDED FOR THE FIRST FOUR HUNDRED SQ. FT. OR FRACTION THEREOF OF THE WATER SURFACE AREA AND ONE SKIMMER FOR EACH ADDITIONAL 400 SQUARE FEET OF SURFACE AREA

FOR SPAS: ONE SKIMMER REQUIRED FOR EVERY 100SF OF SURFACE AREA.

SURFACE AREA OF POOL: _____
 NUMBER OF SKIMMERS REQUIRED: _____
 NUMBER OF SKIMMERS PROVIDED: _____

SKIMMER FLOW RATE

FLOW THROUGH EACH SKIMMER

SKIMMER FLOW (from above) = _____ GPM = _____ GPM
 #SKIMMERS PROVIDED

MUST BE A MINIMUM 25GPM

PIPE SIZE SELECTION

SKIMMER LINE SIZE

SELECT PIPE SIZE THAT GIVES MAXIMUM 6 FPS VELOCITY AT DFR

		BRANCHES						
		1	2	3	4	5	6	7
NUMBER OF SKIMMERS SERVED BY PIPE								
PIPE SIZE								
FLOW IN PIPE								
VELOCITY (FPS)								

RETURN LINE SIZE

SELECT PIPE SIZE THAT GIVES MAXIMUM 8 FPS VELOCITY AT DFR

		BRANCHES						
		1	2	3	4	5	6	7
NUMBER OF INLETS SERVED BY PIPE								
PIPE SIZE								
FLOW IN PIPE								
VELOCITY (FPS)								

MAIN DRAIN SIZE

IF FEATURE FLOW IS THROUGH ADDITIONAL DRAINS, THESE PIPES MUST BE LISTED.
 SELECT PIPE SIZE THAT GIVES MAX. 6 FPS VELOCITY FROM DFR FOR CIRCULATION AND PUMP CURVE MAX FLOW FOR FEATURES.

DFR: _____

PIPE SIZE: _____

VELOCITY: _____

MAIN DRAIN GRATE SELECTION

IF FEATURE FLOW IS THROUGH ADDITIONAL DRAINS, THESE DRAINS MUST LISTED.

PIPE SIZE: _____

GRATE SIZE: _____

FLOW AREA (EACH): _____

TOTAL FLOW (DFR): _____

FLOW RATE GPM (SPEC SHEET): _____

MAXIMUM FLOW OF PUMP (PUMP CURVE): _____

FRAME AND GRATE CATALOG NUMBER: _____

QUANTITY: _____

CALCULATE RETURN LINE LOSS

STATE WHICH CHART USED: Williams and Hazen

BRANCH 1

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 2

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 3

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 4

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

CALCULATE RETURN LINE LOSS (continued)

STATE WHICH CHART USED: Williams and Hazen

BRANCH 5

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

_____ TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 6

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

_____ TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 7

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

_____ TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

FRICITION LOSS DUE TO INLET RESISTANCE AT _____ GPM = FEET

TOTAL RETURN LINE FRICTION LOSS = _____ FEET
 (ENTER ON PAGE 8)

CALCULATE SKIMMER LINE LOSS

STATE WHICH CHART USED: Williams and Hazen

BRANCH 1
 PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____
 _____ ELBOWS X EQUIV. LENGTH _____ = _____
 _____ TEES X EQUIV. LENGTH _____ = _____
 _____ VALVES X EQUIV. LENGTH _____ = _____
 TOTAL EQUIVALENT LENGTH _____ = _____
 FRICTION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 2
 PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____
 _____ ELBOWS X EQUIV. LENGTH _____ = _____
 _____ TEES X EQUIV. LENGTH _____ = _____
 _____ VALVES X EQUIV. LENGTH _____ = _____
 TOTAL EQUIVALENT LENGTH _____ = _____
 FRICTION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 3
 PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____
 _____ ELBOWS X EQUIV. LENGTH _____ = _____
 _____ TEES X EQUIV. LENGTH _____ = _____
 _____ VALVES X EQUIV. LENGTH _____ = _____
 TOTAL EQUIVALENT LENGTH _____ = _____
 FRICTION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 4
 PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____
 _____ ELBOWS X EQUIV. LENGTH _____ = _____
 _____ TEES X EQUIV. LENGTH _____ = _____
 _____ VALVES X EQUIV. LENGTH _____ = _____
 TOTAL EQUIVALENT LENGTH _____ = _____
 FRICTION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

CALCULATE SKIMMER LINE LOSS (continued)

STATE WHICH CHART USED: Williams and Hazen

BRANCH 5

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

_____ TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 6

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

_____ TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

BRANCH 7

PIPE SIZE _____ @ GPM _____ PIPE LENGTH _____ = _____

_____ ELBOWS X EQUIV. LENGTH _____ = _____

_____ TEES X EQUIV. LENGTH _____ = _____

_____ VALVES X EQUIV. LENGTH _____ = _____

_____ TOTAL EQUIVALENT LENGTH _____ = _____

FRICITION LOSS PER 100FT _____ X TOT EQ LENGTH _____ /100 =

FRICITION LOSS OVER THE WEIR AT _____ GPM = FEET

TOTAL SKIMMER LINE FRICTION LOSS = _____ **FEET**
 (ENTER ON PAGE 8)

INTERACTIVE WATER PLAY POOLS/ SPRAY PADS

1. THE MINIMUM SIZE OF THE TANK SHALL BE EQUAL TO THE VOLUME OF TWO OF THE COMBINED FLOW OF ALL THE FEATURE PUMPS AND THE FILTER PUMP.
2. WHEN AN UNDERGROUND RESERVOIR IS UTILIZED, AN AUTOMATIC SKIMMER SYSTEM PROVIDED. A VARIABLE HEIGHT SKIMMER MAY BE USED OR A CUSTOM SURFACE SKIMMER DEVICE MAY BE SUBSTITUTED IF DEEMED APPROPRIATE BY BOTH THE DESIGN ENGINEER AND THE HEALTH AUTHORITY.
3. THE FILTER SYSTEM SHALL BE CAPABLE OF FILTERING AND TREATING THE ENTIRE WATER VOLUME OF THE RESERVOIR TANK WITHIN THIRTY MINUTES.THE FILTER SYSTEM SHALL DRAFT FROM THE TANK AND RETURN FILTERED AND TREATED WATER TO THE TANK THROUGH EQUALLY SPACED INLET FITTINGS.
4. THE FLOW RATE THROUGH THE FEATURE NOZZLES OF THE WATER FEATURES SHALL BE SUCH AS NOT TO HARM THE PATRONS AND SHALL NOT EXCEED TWENTY FEET PER SECOND UNLESS JUSTIFIED BY THE FOUNTAIN SYSTEM MANUFACTURER.

NUMBER OF INLET FITTINGS = SQUARE FEET OF RESERVOIR TANK/300 or PERIMETER OF RESERVOIR TANK/20, WHICHEVER IS GREATER

NUMBER OF INLET FITTINGS = _____ = _____ ROUND TO NEXT WHOLE NUMBER

NOTE:

WHERE WATER IS DRAWN FROM THE POOL TO SUPPLY WATER TO AQUATIC FEATURES THE WATER MAY BE REUSED PRIOR TO FILTRATION IF;

1. THE DISINFECTANT AND pH LEVELS OF THE SUPPLY WATER ARE MAINTAINED AT REQUIRED LEVELS AND THE RATIO OF INTERACTIVE PLAY FEATURE, SLIDE, OR OTHER APPARATUS UNFILTERED WATER TO FILTERED WATER CIRCULATED IN THE RESERVOIR OR POOL SHALL BE NO MORE THAN 3:1 IN ORDER TO MAINTAIN THE EFFICIENCY OF THE FILTRATION SYSTEM, OR
2. THE APPARATUS OR DEVICE SHALL USE ONLY WATER THAT HAS BEEN FILTERED AND DISINFECTED IMMEDIATELY PRIOR TO BEING DISCHARGED INTO THE POOL. THAT INCLUDES, BUT IS NOT LIMITED TO, SLIDES, FOUNTAINS, WATER WHEELS, "MUSHROOMS", AND SQUIRT GUNS.

