



## **BODY ART STUDIO PLAN REVIEW CHECKLIST**

**NAME:** \_\_\_\_\_

**ADDRESS:** \_\_\_\_\_

- Studio constructed to provide for privacy for customer this can include a washable screen.
- Parlor, the room where the body art procedure is performed, is separate from the waiting area.
- Each parlor has a minimum of 45 square feet floor space.
- Walls in parlors light colored up to five feet and painted or covered to allow easy and effective cleaning.
  - List material \_\_\_\_\_
  - List color \_\_\_\_\_
- Parlor floors constructed of an adequate non-absorbent material for effective cleaning.  
**Traditionally adequate materials have been sealed concrete, laminate flooring, vinyl composite tile (VCT), poured epoxy, and quarry tile.**
  - List material \_\_\_\_\_
- A restroom separate from the parlor provided for customers.
- The chair or other piece of furniture where body art procedures (tattooing or body piercing) are occurring is no more than fifteen feet of unobstructed distance from a hands free hand sink with hot and cold running water. A door is an obstruction.
- A separate **equipment washing sink\*** with hot and cold running water is provided and is stainless steel with rounded interior corners.
- Parlor and equipment handling areas have adequate lighting.
- Cabinets or similar item for supplies provided for each body artist.

- All worktables, chairs, and other pieces of furniture where body art procedures are occurring are constructed of materials and are in sufficient condition so that they are smooth, light colored, nonporous, nonabsorbent, corrosion resistant, and easily sanitized.
  - List material \_\_\_\_\_
  - List color \_\_\_\_\_
- A manufacturer's specification sheet showing the **autoclave\*** is a medical instrument sterilizer is provided.
- Autoclave operator's manual\*** present at the body art studio.
- All waste containers have self-closing lids and lined with plastic bags.
- A sharps container at every work station which is a rigid and puncture resistant container that is leak proof on the sides and bottom and has a self-closing lid and is marked with international biohazard symbol and has the words biohazard printed on it.
- A professional engineer or registered architect stamp is on the plan.

**\* These items are not required if tattoo tubes and piercing forceps are commercially pre-packaged, pre-sterilized and single-use.**

---

Body Art Studio Owner/Print Name

---

Signature

---

Date